

CERTIFICATE OF CONFORMITY

CERTIFICATO DI CONFORMITÀ

Issued to: GoodWe Technologies Co., Ltd.
No.90 Zijin Rd., New District, Suzhou, 215011, China

For the product: Grid-Tied PV Inverter

Trade name: **GOODWE**

Type/Model: GW100K-GT, GW110K-GT, GW125K-GT

Ratings: See Annex

Manufactured by: GoodWe Technologies Co., Ltd.
No.90 Zijin Rd., New District, Suzhou, 215011, China

Requirements: TOR Erzeuger Type B Version 1.2:2022-04-11
OVE-Richtlinie R 25:2020-03-01

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 6185613.50

The examination has been carried out on one single specimen of the product. The Attestation does not include an assessment of the manufacturer's production. Conformity of this production with the specimen tested by DEKRA is not the responsibility of DEKRA.

This Test Certificate expires at the latest on 2029-08-16 or expires upon withdrawal of one of the above mentioned standards.

Arnhem, 16 August 2024

Number: 6185613.01COC

DEKRA Testing and Certification (Shanghai) Ltd.


Cliff Lin
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed

DEKRA Testing and Certification (Shanghai) Ltd.
No.250, Jiangchangsan Road, Jing'an District, Shanghai, 200436 People's Republic of China
T +86 21 6056 7600 F +86 21 6056 7555 www.dekra-product-safety.com
ESA-CER-F021 v4.1



Document no. : 6185613.01COC

Test basics:

TOR Erzeuger Type B Version 1.2: 2022-04-11

Connection and parallel operation of type B power generating modules

OVE-Richtlinie R 25: 2020-03-01

Test requirements for generator units to be connected to and operated in parallel with low-voltage distribution networks

- 5.1 Testing the network perturbations
- 5.2 Testing the symmetry behavior of three-phase inverters
- 5.3 Testing the behavior of the generating unit on the network
- 5.4 Testing the automatic activation point
- 5.5 Testing the connection conditions and synchronization
- 5.6 Proof of robustness and dynamic network support

Ratings of product:

Operating temperature range: - 30°C to + 60°C

Protective class: I

Ingress protection rating: IP66

OVC: DC II / AC III

Power factor range (adjustable): 0.8 leading...0.8 lagging

GW100K-GT

PV Input: Umax: 1100 Vdc, UMPPT: 180-1000 Vdc, I_{max}: 8*42 A, I_{sc} PV: 8*52.5 A

Output: U_r: 220 / 380 Vac, 230 /400 Vac, 3L / N / PE or 3L / PE,

50 / 60 Hz, I_{max}: 167.1 A, Pr: 100 kW, Sr: 100 kVA, S_{max}: 110 kVA

GW110K-GT

PV Input: Umax: 1100 Vdc, UMPPT: 180-1000 Vdc, I_{max}: 10*42 A, I_{sc} PV: 10*52.5 A

Output: U_r: 220 / 380 Vac, 230 /400 Vac, 3L / N / PE or 3L / PE,

50 / 60 Hz, I_{max}: 183.4 A, Pr: 110 kW, Sr: 110 kVA, S_{max}: 121 kVA

GW125K-GT

PV Input: Umax: 1100 Vdc, UMPPT: 180-1000 Vdc, I_{max}: 10*42 A, I_{sc} PV: 10*52.5 A

Output: U_r: 220 / 380 Vac, 230 /400 Vac, 3L / N / PE or 3L / PE,

50 / 60 Hz, I_{max}: 199.4 A, Pr: 125 kW, Sr: 125 kVA, S_{max}: 137.5 kVA

--END--